

Certificate



Intertek

for European Product Safety

Reference No. 1124105

Circuit-breaker for overcurrent protection

Type designation NB1-63

Certificate holder **Zhejiang Chint Electrics Co., Ltd.**
No.1 Chint Road, Chint Industrial Zone, North Baixiang
Yueqing, Zhejiang Province
CHINA

The product complies with the standard(s) EN 60898-1:2003 and A1+A11+A12

Date of expiry 25 November 2016


EU Directive information *The product satisfies the provisions for CE marking according to the Low Voltage Directive 2006/95/EC.*

Additional information in Appendix.

Certification Body Intertek Semko AB, Product Certification

Place Kista - Stockholm

Signed


Bo Berglöf

Date 25 November 2011
Page 1 of 3

**Intertek
Appendix***Reference No. 1124105**Technical data*

<i>Type designation</i>	NB1-63
<i>Rated voltage (V)</i>	240/415
<i>Rated current (A)</i>	1, 2, 3, 4, 6, 8, 10, 13, 16, 20, 25, 32, 40, 50, 63
<i>Frequency (Hz)</i>	50/60
<i>IP-Class</i>	20
<i>Poles No</i>	1P
<i>BRAND name:</i>	CHNT
<i>Product information</i>	B-, C- & D- Type Ics= 6000A Icn= 6000A Energy limiting class 3

<i>Type designation</i>	NB1-63
<i>Rated voltage (V)</i>	240
<i>Rated current (A)</i>	1, 2, 3, 4, 6, 8, 10, 13, 16, 20, 25, 32, 40, 50, 63
<i>Frequency (Hz)</i>	50/60
<i>IP-Class</i>	20
<i>Poles No</i>	1P+N
<i>BRAND name:</i>	CHNT
<i>Product information</i>	B-, C- & D- Type Ics= 6000A Icn= 6000A Energy limiting class 3

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

**Intertek
Appendix**

Reference No. 1124105

Type designation	NB1-63
Rated voltage (V)	415
Rated current (A)	1, 2, 3, 4, 6, 8, 10, 13, 16, 20, 25, 32, 40, 50, 63
Frequency (Hz)	50/60
IP-Class	20
Poles No	2P, 3P, 3P+N, 4P
BRAND name:	CHINT
Product information	B-, C- & D- Type Ics= 6000A Icn= 6000A Energy limiting class 3

Manufacturing site(s) Zhejiang Chint Electrics Co., Ltd.
No.1 Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang
Province, P.R. China

Safety related parts of the user instructions shall be written in a language acceptable to the country where the product is to be used.

This certificate, which includes production control, is considered to constitute sufficient support for an EC Declaration of Conformity and CE marking of the products according to the Low Voltage Directive 2006/95/EC.

Certification Body Intertek Semko AB, Product Certification Place Kista - Stockholm

Signed


Bo Berglöf

Date 25 November 2011

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.