

# RCC

## (REGULATORY COMPLIANCE CERTIFICATE)

ISSUED TO

**ZHEJIANG CHINT ELECTRICS Co. Ltd**

IN TERMS OF SANS 10142 CLAUSE 4,  
ISSUED BY

**National Regulator for Compulsory Specifications**

*PRODUCT: AIR CIRCUIT BREAKER (CHINT)*

*NAI-1000;  $U_c=400/690Vac$ ,  $U_i=800Vac$ ,  $U_{imp}=8kV$ ,  $I_c=200A$ ,  $400A$ ,  $630A$ ,  $800A$ ,  $1000A$ ,  $50/60Hz$ ,  
3P, 4P*

**Test Laboratory:**

KEMA

**Test Report No(s):**3300977.50


**In accordance to(Standards):**

IEC 60947-2: 2004

**RCC No:** 1304677

**Period of Validity**

22/04/2013 to 22/04/2015

  
NRCS-Electro-Tech General Manager

  
DATE

20/04/2013

# RCC

## (REGULATORY COMPLIANCE CERTIFICATE)

ISSUED TO  
**CONSOLIDATED ELECTRICAL DISTRIBUTOR (PTY) LTD**

IN TERMS OF SANS 10142 CLAUSE 4.  
ISSUED BY

**National Regulator for Compulsory Specifications**

PRODUCT: AIR CIRCUIT-BREAKERS (CHINT) NAI-2000 series, NAI-3200 series, NAI-6300 series;

$U_c = 400V, 690V; (3P, 4P); U_i = 1000V; U_{imp} = 12kV;$

$I_n = 630, 800, 1000, 1250, 1600, 2000, 2500, 3200, 4000, 5000, 6300A;$

$I_{cs} = 50, 40kA / 65, 65kA / 100, 75kA; I_{cu} = 80, 50kA / 80, 65kA / 120, 85kA; 50/60Hz; Category B; IP20$

### Test Laboratory:

DEKRA Testing Services Co., Ltd

Test report no: 3303046.50/51/52

**RCC No: 1310749A**

### In accordance to(Standards):

IEC 60947-2:2006 + A1:2009

### Period of Validity

01/10/2013 to 01/10/2015



11/10/2013

DATE

*[Signature]*

NRCS - Electrotechnical General Manager.