

C E R T I F I C A T E



of Conformity
Low Voltage Directive 2006/95/EC

Registration No.: AN 50203786 0001

Report No.: 15043659 001

Holder: Zhejiang Chint Electrics Co., Ltd.
No.1,
Chint Road, Chint Industrial Zone,
North Baixiang
Yueqing, Zhejiang Province 325603
P.R. China

Product: Circuit Breaker
(Air Circuit-breaker)

Identification: Type Designation : NA1-3200 NA1-4000
Ratings : 3200/2500/2000A(3/4P) 4000A(3P)
Ics/Icu: 80/100kA(400V); 65kA(690V)
Icw: 80kA, 1s (400V); 50kA, 1s(690V)
Serial No. : Engineering samples
Remark: Refer to test report 15043659 001 for details.

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with all revision of Annex I of Council Directive 2006/95/EC, in its latest amended version, referred to as the Low Voltage Directive. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to Annex III of the Directive.

Certification Body

Qingdao, 25.05.2011





Dipl.-Ing. F. He

TÜV Rheinland/CCIC (Qingdao) Co., Ltd. - Qingdao 266071 - P.R.China

CE The CE marking may be used if all relevant and effective EC Directives are complied with. CE

Test Verification of Conformity

On the basis of the referenced test report(s), sample(s) of the below product have been found to comply with the harmonized standards and Directives listed on this verification at the time the tests were carried out. Other standards and Directives may be relevant to the product.

Once all product relevant  mark directives are verified in compliance, the manufacturer may indicate compliance by signing a Declaration of Conformity themselves and applying the mark to product identical to the test sample(s) if the product complies with all relevant CE mark Directives requirements.

Applicant Name & Address : Zhejiang Chint Electrics Co, Ltd.
No.1, Chint Road, Chint Industrial Zone, North Baixiang,
Yueqing, Zhejiang Province, P.R.China

Manufacturing site Name & Address : Same as applicant

Product(s) Tested : ACB Accessary
(Undervoltage release, Shunt release, Auxiliary contactor,
Closing coil and stored energy motor)

Ratings and principal characteristics : See Annex

Model(s) : NA1-1000, NA1-2000~6300

Brand name : CHINT 

Relevant Standard(s) / Specification(s) / Directive(s) : EN 60947-5-1: 2004 + A1:2009;
EN 60947-2:2006+ A1:2009

Verification Issuing Office Name & Address : Intertek Testing Services Shanghai
Building No.86, 1198 Qinzhou Road (North), Shanghai
200233, China

Verification Number : 130401930SHA-V1

Report Number(s) : 130401930SHA-001~-005

NOTE 1: This verification is part of the full test report(s) and should be read in conjunction with it.

This Verification is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to copy or distribute this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results referenced from this Verification are relevant only to the sample tested. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.



Oliver Wei
Manager
July 30, 2013