

# Zertifikat

# Certificate



Zertifikat Nr. Certificate No.  
R 50177783

Blatt Page  
0001

Ihr Zeichen Client Reference  
D.L.

Unser Zeichen Our Reference  
01-MR- 15032003 003

Ausstellungsdatum  
12.04.2010

Date of Issue  
(day/mo/yr)

**Genehmigungsinhaber License Holder**  
Zhejiang Chint Electrics Co., Ltd.  
Chint High-tech Industrial Zone  
North Baixiang  
Wenzhou, Zhejiang 325603  
P.R. China

**Fertigungsstätte Manufacturing Plant**  
Zhejiang Chint Electrics Co., Ltd.  
Chint High-tech Industrial Zone  
North Baixiang  
Wenzhou, Zhejiang 325603  
P.R. China

## Prüfzeichen Test Mark

Geprüft nach Tested acc. to  
EN 60947-2:2006



**Zertifiziertes Produkt (Geräteidentifikation)**  
**Certified Product (Product Identification)**

**Lizenzentgelte - Einheit**  
**License Fee - Unit**

### Leistungsschalter (Moulded Case Circuit-breaker)

Type Designation	: CB-125	5
	DZ158-125 (Chint)	1
Nature of Supply	: 1) AC 50/60Hz	
	2) DC	
Number of Protection Poles:	1) 1-pole	2/3/4-pole
	2) 1-pole	2-pole
Rated Operational Voltage	: 1) 240V/415V	415V
	2) 60V/110V	125V/220V
Rated Ultimate Short Circuit Breaking Capacity	: 1) 10kA	
	2) 20/10kA	
Rated Service Short Circuit Breaking Capacity	: 1) 7,5kA	
	2) 15/7,5kA	
Rated Current	: 63A; 80A; 100A; 125A	



Continued on page 0002

6

ANLAGE (Appendix): 1; 1.1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.  
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

Zertifizierungsstelle

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg  
Tel.: (+49/221) 8 06 - 13 71 e-mail: cert-validity@de.tuv.com  
Fax: (+49/221) 8 06 - 39 35 http://www.tuv.com/safety

Dipl.-Ing. F. He